

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 6603Date: 02/09/2024

It is certified that an inspection team headed by Sh. Raghuvir Singh,
Junior Engineers (Name of Officers
with designation) from Public Health Engg. Divn-No.1, Faridabad (Name of
Department/Office) inspected the G. C. M. Public Sr. Sec. School
Nawada (Tigaon) Faridabad (Name & Address of
the School) on 19/06/2024 and found that the G.C.M. Public Sr.
Sec. School, Nawada (Tigaon) Faridabad (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 31/03/2025

Signature with Seal: Executive Engineer
Public Health Engineering
Name Division No. 1, YMCA Road
Sector-11, Faridabad
Designation: _____

To

Principal,
GCM Public Sr. Sec. School,
Nawada Tigaon, Faridabad

(Name & Address of the Institution)

B. Singh
President
Shree Gian Chand Memorial Shiksha Samiti
Nawada, Ballabgarh

Principal
GCM Public Sr. Sec. School
Nawada, Tigaon, Faridabad

Memo No:- 719

Date:- 24/06/2024

Certificate
No: TC-9082

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : FBD/01003/6/2024 / Private	Sample Details	Date & Time
Sender : G.C.M PUBLIC SR.SEC.SCHOOL32786	Collected By	G.C.M PUBLIC S...
Location : Vill- Nawada Tigaon	Collection Date	19/06/2024 at 14:40
Sample Description : Drinking Water	Received at lab	19/06/2024 at 14:59
Latitude / Longitude : 77.381818 / 28.337822	Analysis Start Date	19/06/2024
	Analysis End Date	20/06/2024
	Sample Quantity	1 L

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	154	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
2	Total Hardness as CaCO ₃	52	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
3	Calcium as Ca	11.22	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	5.83	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
5	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA
6	Chloride as Cl	64.98	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
7	Sulphate as SO ₄	21	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
8	Fluoride as F	0.21	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
9	Nitrate as NO ₃	1.73	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
10	pH @ 25°C	6.69	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
11	Total Alkalinity	50	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless-until specifically-requested by the customer for retaining over a longer period.



Sample analyzed by :

VANDANA DESWAL, CHEMIST
DISTRICT WATER TESTING LABORATORY FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

President
Shree Gyan Chand Memorial Shiksha Samiti
Nawada, Ballabgarh

Principal
GCM Public Sr. Sec. School
Nawada, Tigaon, Faridabad

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, FARIDABAD

PHED
Haryana

Website :- <https://phedharyana.gov.in/>

Memo No:- 723

Date:- 24/06/24

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FBD/01004/6/2024	Sample Details	Date & Time
Sample Classification:	Private	Collected By	G.C.M PUBLIC S...,9891027555
Sender:	G.C.M PUBLIC SR.SEC.SCHOOL32787	Collection Date	19/06/2024 at 14:45
Location :-	, Vill- Nawada Tigaon	Received at lab	19/06/2024 at 15:01
Latitude :-	77.381470	Tested at Lab	24/06/2024
Longitude :-	28.338668		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "POTABLE"



Vandana
VANDANA DESWAL, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

-----End of Report-----

By...
President
Shree Gian Chand Memorial Shiksha Samiti
Nawada, Ballabgarh

...
Principal
GCM Public Sr. Sec. School
Nawada, Tigaon, Faridabad